



Examination Certificate

inspection order 20200239-A

for

fischerwerke GmbH & Co. KG

*Klaus-Fischer-Str. 1
72178 Waldachtal
Germany*

Product description:

Test specimens: concrete screws
Designation: FBS II CP 10 x 100
Coating: fischer "corrosion protection" coating

Test conditions:

- 480 hrs. constant condensation test according to DIN EN ISO 6270-2 CH:2018

Test methods:

- Accredited test methods to DIN EN ISO/IEC 17025:2005

Test result:

- The fischer corrosion protection coating of the "FBS II CP 10 x 100" concrete screws met the requirements for the constant condensation test for the following classification in accordance with DIN EN ISO 12994-6:2018:
 - C3 very high and
 - C4 high and
 - C5 medium

Solingen, dated 13th October 2020
IGOS GmbH & Co. KG

Dipl.-Ing. Josef Andrek
Managing Director

Sarah Nieder
Technician Electroplater

www.igos.de · info@igos.de

Beratung
Galvanotechnik
Korrosionsprüfung
Chemische Analysen
Schadensanalysen
Schichtanalysen
Gutachten
Schulung



Examination Certificate

inspection order 20200237-A

for

fischerwerke GmbH & Co. KG

*Klaus-Fischer-Str. 1
72178 Waldachtal
Germany*

Product description:

Test specimens: Concrete Screws
Designation: FBS II CP 10 x 100
Coating: fischer "corrosion protection" coating

Test conditions:

- 15 cycles Nordtest Method NT MAT 003:2002-05

Test methods:

- Accredited test methods to DIN EN ISO/IEC 17025:2005

Test result:

- The fischer corrosion protection coating of the "FBS II CP10 x 100" concrete screws met the requirements for the Nordtest Methode NT MAT 003:2002-05 for the following classification :
 - Corrosion classification 4

Solingen, dated 13th October 2020
IGOS GmbH & Co. KG

Dipl.-Ing. Josef Andrek
Managing Director

Sarah Nieder
Technician Electroplater

www.igos.de · info@igos.de

Beratung
Galvanotechnik
Korrosionsprüfung
Chemische Analysen
Schadensanalysen
Schichtanalysen
Gutachten
Schulung

The logo for Fischer, featuring the word "fischer" in a bold, white, sans-serif font on a red rectangular background. To the right of the text is a small black icon of a fish.

Examination Certificate

inspection order 20200238-2

for

fischerwerke GmbH & Co. KG

*Klaus-Fischer-Str. 1
72178 Waldachtal
Germany*

Product description:

Test specimens: concrete screws
Designation: FBS II CP 14 x 125
Coating: fischer "corrosion protection" coating

Test conditions:

- 2016 hrs. salt spray test to DIN EN ISO 9227 NSS:2017

Test methods:

- Accredited test methods to DIN EN ISO/IEC 17025:2005

Test result:

- The fischer corrosion protection coating of the "FBS II CP 14 x 125" concrete screws met the requirements for the salt spray test for the following classifications in accordance with DIN EN ISO 12994- 6:2018:
 - C4 very high and
 - C5 high

Solingen, dated 13th October 2020
IGOS GmbH & Co. KG

Dipl.-Ing. Josef Andrek
Managing Director

Sarah Nieder
Technician Electroplater

www.igos.de · info@igos.de

Beratung
Galvanotechnik
Korrosionsprüfung
Chemische Analysen
Schadensanalysen
Schichtanalysen
Gutachten
Schulung