

Declaration of performance

FD60v01

Producer: AS VILJANDI AKEN JA UKS, reg no 10052966, Puidu 6, 71020 Viljandi, Estonia

Hereby declares that

Product: internal door **FD60**

Product description: hinged timber leaf hung in timber frame, fire resistant single leaf wooden door.

Intended use or uses of the construction product: for closing entrances between the fire compartments of heated working and living premises.

Systems of assessment and verification of constancy of performance of the construction product: system 1 and 3

Produced: AS Viljandi Aken ja Uks, Puidu 6, 71020, Viljandi, Estonia

Confirms with following characteristics:

No	Characteristics	Test or calculation standard	Classification standard	Unit	Class/ value	Report	Notified body*
1.	Fire resistance	EN 1634-1	EN 13501-2	Class	E1i60	CLA-187-21-0001	1336
2.	Sound insulation	EN ISO 10140-2	ISO 717-1	dB	31	VTT-S-07800-13	0809
3.	Resistance to repeated opening and closing	EN 1191	EN 12400	Class	6	No. 042 SF/14P	2018
4.	Self-closing	EN 1191	EN 14600	Class	C5	No. 042 SF/14P	
5.	Smoke control	EN 1634-3	EN 13501-2	Class	Sa/S ₂₀₀	5P04141	0402
6.	Burglar resistance	EN 1630	EN 1627	Class	RC3	082 SF/21 IS	2018

***Notified body:**

1336 – Inspecta Estonia OÜ, Teaduspargi 8, 12618 Tallinn, ESTONIA

0809 – VTT Technical Research Centre of Finland P.O. Box 1000, FI-02044 VTT, Finland

2018 – KTU Science Laboratory of Building Thermal Physics, Tunelio g. 60, LT-44405 Kaunas, Lithuania

0402 – SP Technical Research Institute of Sweden, Box 857, SE-501 15 Borås, Sweden

- Products are produced according to standardisation proposal SFS 4434 in case it is not in conflict with European standards.
- Products are installed according to the product installation and maintenance instructions.
- “Warranty conditions for doors and windows sold by AS Viljandi Aken ja Uks” apply to the sale of products.

AS Viljandi Aken ja Uks



Veiko Põldsaar
R&D Manager
23.08.2022